

Horry Electric Cooperative, Inc.

A Touchstone Energy® Cooperative 

All meter bases connected to the Horry Electric Cooperative system must meet certain specifications in order for power to be connected.

Approved Manufacturers and Models - 3 phase meter sockets

Effective February 12, 2009

Please visit horryelectric.com for the most up-to-date list

	Culter Hammer/Eaton	Milbank	Siemens/L&G	Durham/Square D
200 amp, with lever bypass, lay-in type lugs on line & load side	UTH7213TCH UTH7213UCH	U 7423-RXL U4701-RXL	40407-025	T-H 7213V
200 amp, with lever bypass, 3/8" studs on line & load side	UTH7210UCH	U 9761-RRL	47607-01FL	UT-H7230Z
320 amp, with lever bypass, 3/8" studs on line & load side	UTH7330UCH	U 2120-X U2594-X	47407-02	T-H 7330U
480 amp bolt-in, type K-7T, with 1/2" studs on line and load side	CH9504K7	UA4667-XT-9504	9817-9504	N/A

notes

U in front of Durham part # puts a UL sticker on the base

red text are bases we are currently using